



PLUGS

ANCHOR SCHEDULE FOR VERTICAL DOWNWARD BENDS	
SIZE	SIZE
4"Ø	#3 BAR
6"Ø	#4 BAR
8"Ø	#5 BAR
10"Ø	#6 BAR
12"Ø	#7 BAR
14"Ø	#8 BAR
24"Ø	3"x1/2" FLAT

MECHANICAL JOINT BOLT
AND NUTS ON PLUG SHALL
BE ACCESSIBLE AFTER
THRUST BLOCK IS POURED

**THRUST BLOCKS DESIGNED FOR 150 LB. PER SQ. IN. TEST
PRESSURE AND 2000 LB. PER SQ. FT. SOIL PRESSURE.**

*** MIN. CONC. ANCHORS WITHOUT BACKFILL AND NO
GROUND WATER CONDITION.**

- NOTE:**
WHEN THE EXISTING UTILITY IS A SANITARY SEWER, SANITARY SEWER
LINE SHALL BE ENCASED IN 6" OF CONCRETE 10 FEET BEFORE AND
AFTER THE POINT OF CROSSING.



<div style="text-align: center;"> <p>SHEET TITLE</p> <p>WATER SYSTEM DETAILS AND NOTES</p> </div>	INITIAL DATE	JOB NO.
	OCT. 15, 2019	01895.0053
	SCALE	B/O
	NOT TO SCALE	
	DRAWN	SHEET NO.
C.Y. / F.M.	<div style="text-align: center;"> <p>C-17</p> <p>79 OF 103</p> </div>	
CHKD.		
L.A.D.		