



McGOEY, HAUSER and EDSALL
CONSULTING ENGINEERS D.P.C.

MARK J. EDSALL, P.E., P.P. (NY, NJ & PA)
MICHAEL W. WEEKS, P.E. (NY, NJ & PA)
MICHAEL J. LAMOREAUX, P.E. (NY, NJ, PA, VT & VA)
MATTHEW J. SICKLER, P.E. (NY & PA)
PATRICK J. HINES

Regional Office
111 Wheatfield Drive, Suite 1
Milford, Pennsylvania 18337

(570) 296-2765
fax: (570) 296-2767
e-mail: mhepa@mhepc.com

Principal Emeritus:
RICHARD D. McGOEY, P.E. (NY & PA)
WILLIAM J. HAUSER, P.E. (NY, NJ & PA)

TOWN OF THOMPSON **TECHNICAL REVIEW COMMENTS**


PROJECT NAME: Thompson Education Center – Well Drilling Plan
PROJECT NUMBER: 95-56; 13-42
PROJECT LOCATION: Town of Thompson
DATE: 10 May 2016
REVIEWED: SWPPP

1. The applicant's engineer has provided a SWPPP that only addresses Erosion and Sediment Control. It is the opinion of this office that a full SWPPP is required to address water quantity, water quality, channel protection volume and runoff reduction techniques. According to the NOI provided in the SWPPP, the project area is forested and 3.46 acres will be disturbed. The 3.46 acres of forested ground will change to gravel roads, grassed areas, etc. According to Hydro-Cadd, gravel roads are represented with a curve number of 96. Provide a full SWPPP or provide applicable reasoning why a full SWPPP is not warranted.
2. Address the requirements of the Office of Parks, Recreation and Historic Preservation in the SWPPP.
3. Provide a grading plan for the roads. A contour interval of two feet is recommended.
4. Delineate and state the limits of disturbance on the plans.
5. Show larger scale plans around the well heads. The well heads appear to be that appear very close to the NYS wetland adjacent areas.
6. A "Construction Sequence" is provided on Plan Sheet 1 of 2. An initial step (Step 1) should be added that states "Schedule a Pre-Construction Meeting with Town Officials, including Town Engineer Representative at least once a week prior to onsite earth disturbance or equipment staging."

Should you require any additional information or have any further questions, please do not hesitate to contact our office.

Respectfully submitted,

McGOEY, HAUSER & EDSALL
CONSULTING ENGINEERS, D.P.C.

A handwritten signature in black ink, reading "Scott M. Quinn", written over a horizontal line.

Scott M. Quinn, P.E.

Senior Engineer

SQ/amn

F:\1995\95-56 SWPPP Reviews\2016\Thompson Education Center\05-09-16.doc