

Dear Tommy Decker

I checked out the beginning of the roadway this morning at the new Education Center. As you and I, we talked about what the width of the roadway should be to get in there. 12 feet wide is more than enough room for a piece of fire apparatus to gain entry into the drilling of the wells if there should be any fire suppression needed. If you need anymore information from the Rock Hill Fire Dept. please let me know. The road leading in must have shale also for the weight of the fire trucks.

Kris Gwiozdowski, Chief
Rock Hill Fire District
PO Box 116
Rock Hill, NY 12775-
Cell-845-701-5598
www.rockhillfiredept.com
mfdcar1@gmail.com